



The Woodlands Township

Invitation For Bid Gate Automation & Maintenance for Township Transit Facilities Contract No. C-2023-0192

Addendum #1 July 21, 2023


Note: This Addendum must be included as part of the proposal documents.

Included in this addendum:

- Email questions received 7/21/2023

Questions:

1. Are we able to reuse existing slide gates in locations that allow it, or are we strictly replacing all listed gates?
 - a. Yes, existing gates can be reused.
2. Are you open to hardwired gate operators instead of solar powered? I highly recommend using hardwired gate operators as they are more reliable and will not cause nearly as many issues in the future (especially with safety loops, keypads, ect. which need steady power that is not always supplied as needed by solar panels)
 - a. Bidders may provide hardwired gate operators instead of solar/battery powered as an alternate pricing option if they so choose to. Please ensure pricing is inclusive of all costs associated with boring/hardwiring from the closest power source as on some sites, this may be the building.
3. Some locations will need fence layout changes in order to accommodate new slide gates. Are we allowed to make minor changes to existing fence layouts if needed?
 - a. Yes, changes to existing fence layouts at any of the sites is acceptable. There is the option of complete removal of the pedestrian gate at the “Combined Commuter Bus Gate” at the Research Forest Park and Ride location if need to accommodate a sliding instead of swing gate.



4. The existing opening for gate 4A/4B at Sawdust Park & Ride is 26' but the scope of work calls for a new 36' wide gate. Are we extending the gate opening past the curb? Or are we keeping the 26' wide opening (curb to curb)?
 - a. It appears from our records that the 36' in the bid tabulation is a typo and should read 26'. Please note that all measurements within the Bid are estimates and should be field verified by bidder prior to submitting the bid.

This Addendum must be Signed & Returned with your submittal.

Signature

Name (please print)

Date

Company