



The Woodlands Township

Request for Design/Build Proposal

C-2023-0319

Addendum 1

November 3, 2023

Note: This Addendum shall be included as part of the Bid Form Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form and on the Bid Tabulation. Failure to do so may subject the Bidder to Disqualification.

1. Do the concrete pylons need to be removed for this project on the current permanent dock?

If the design/ build allows to remain in place and meets other specifications, the concrete pylons can remain in place.

2. What is the freeboard specification for the floating docks?

6 inches

3. How long is the Northshore Boat House ramp for delivery purposes?

The overall boat ramp at North Shore dock is 48 feet long. 25 feet of that is in the water and at the point where it ends the water is 4'4" deep.

4. Does the project need to include cleats and continuous dock guard?

Yes

5. Can the center floating dock location be altered?

Yes, the center floating dock location can be shifted slightly east to allow for more space between dock corners.

ACKNOWLEDGMENT - Please sign below indicating that you, the Contractor, received and reviewed the Addendum and included additions or deletion herein in the final bid. This form shall be submitted with the Bid Tabulation Form.

Vendor:

By: _____

Title: _____

Date: _____

Telephone: _____