



The Woodlands Township

**Invitation For Bid
Construction of Trolley Stops
Contract No. C-2022-0482**

Addendum #2

February 1, 2023

Note: This Addendum must be included as part of the proposal documents.

1. Questions from Pre-Bid Meeting:

Q. Will the signs for the trolley stop be provided by the Township?

A. No, the contractor will need to recreate the components of the sign however, the graphics will be provided. The materials are up to the contractor.

Q. Is there color on the concrete?

A. No, but the pavers in some areas have various tones. It will be up to the contract to do the upmost to match tone.

Q. Do you have traffic control specifications?

A. Contractor is required to follow TXDOT traffic control standards. Any work conducted in the right of way will require Montgomery County approval prior to commencement.

Q. Do you have irrigation location information?

A. We do not have exact map of the irrigation locations. The contractor will preferably tie into the Township's irrigation system and work with the Township staff to determine process.

Q. What should we do if we have conflicts with tree root balls during construction?

A. We advise that you do not cut through any large tap roots. If you do run into any potential tree conflicts, notify Township staff and work with a landscape architect prior to the commencement of work.

Q. Is there a set number of calendar days for the project? Will Pavilion and other seasonal Town Center events be taken into consideration?

A. There is not set number of calendar days for the project. Due to the high activity level of the area, upon contract execution, a construction schedule will be determine that accommodates seasonal activities in and around Town Center.

This Addendum must be Signed & Returned with your submittal.

Signature

Name (please print)

Date

Company